

CHECKLIST FOR SELF-SERVICE STATIONS

All code references are to FAC 69-49, NFPA 1, NFPA 30A, NFPA 30.

- 1) Y _____ N _____ N/A _____
All self-service gas stations shall have **at least one attendant on duty** & present on premises of station when open to public. (69-49.004)
- 2) Y _____ N _____ N/A _____
Accurate **daily inventory records** shall be maintained on premises or available within 24 hours on all Class 1 liquids & diesel fuel storage tanks for indication of possible leakage. (NFPA 1:30.2.2.1.5)
- 3) Y _____ N _____ N/A _____
A clearly **identified & easily accessible switch(es)** shall be provided at a location remote from dispensing devices, acceptable to AJHJ, not less than 20 feet but not more than 100 feet that will **shut off power** to all dispensing devices in event of emergency. (NFPA 1:42.2.5.7)
- 4) Y _____ N _____ N/A _____
Dispensing devices shall either be mounted on concrete island otherwise **protected against collision damage**. (NFPA 1:42.2.5.3.4)
- 5) Y _____ N _____ N/A _____
Dispensing devices used to fill portable containers with **Kerosene, LPG, LNG, CNG** shall be at least 20 feet away from Class 1 liquids. (NFPA 1:42.2.5.3.5)
- 6) Y _____ N _____ N/A _____
During **maintenance to Class 1 dispensing devices**, all vehicle traffic shall be prevented from coming within 20' of repair work. (NFPA 1:42.2.5.3.6(4))
- 7) Y _____ N _____ N/A _____
Portable **containers of 12 gallon capacity or less** shall not be filled while they are in or on a motor vehicle or marine craft. (NFPA 1:42.2.7.3.3)
- 8) Y _____ N _____ N/A _____
Crankcase drainings & **liquids shall not be dumped** into sewers or ground & be stored in approved containers. (NFPA 1:42.2.7.6.1)
- 9) Y _____ N _____ N/A _____
Provisions shall be made in the area to **prevent spilled liquids** from flowing into the interior of service station buildings. (NFPA 1:42.2.6.3)

10) Y _____ N _____ N/A _____

One or more **40-BC Extinguisher** shall be located within 100' of any pump, underground fill pipe opening, and lubrication or service room. (**NFPA 1:42.2.7.5.2**)

11) Y _____ N _____ N/A _____

If fire extinguisher is installed & subject to conditions of physical damage such as environment, it shall be protected. (**NFPA 1:13.6.3.9**)

12) Y _____ N _____ N/A _____

Signs provided at pumps:

1. WARNING-IT IS UNLAWFUL AND DANGEROUS TO DISPENSE GASOLINE INTO UNAPPROVED CONTAINERS.
2. NO SMOKING
3. STOP MOTOR (**NFPA 1:42.2.7.5.4**)